

**TOWN OF BLIND RIVER
REQUEST FOR PROPOSAL
FOR WELL REHABILITATION 2023
CONTRACT No. 23-0803**

**ADDENDUM 1
MAY 19, 2023**

This addendum shall form part of the Contract Documents. The Addendum issued shall be indicated in Appendix D on the Schedule of Items and Prices, of the Request for Proposal documents.

1.01 Clarifications

The Town acknowledges that bidders are not responsible for the conditions of the original well installation, the aquifer formation or water quality, and therefore the rehabilitation works are to be completed with the understanding that bidders will attempt to restore capacity and performance using experienced crews and accepted procedures. There is no guarantee of performance results.

Should the results of the post rehab stop start tests and/or turbidity tests be unacceptable to the Town, then the contractor may be asked to undertake additional well development and repeat the start-stop pump test and sampling until acceptable quality of water is demonstrated. The additional work shall be discussed with the Town in advance and shall be paid for on an hourly basis at the rate provided. The hourly rate shall be identified in ink, on the Schedule of Items and Prices to be submitted as part of the bid.

1.02 Closing Date Extension

The closing date is hereby extended to June 2nd, 2023, at 2:00pm local time.

End of Addendum 2